# TEST REPORT

| | |
|---|---|
| Report No.: | BCTC2110418681E |
| Applicant: | SANWAY AUDIO EQUIPMENT CO LIMITED |
| Product Name: | Class-D Power Amplifier |
| Model/Type reference: | DA18K4 |
| Tested Date: | 2021-11-13 to 2021-11-25 |
| Issued Date: | 2022-06-22 |

**Shenzhen BCTC Testing Co., Ltd.**

| | |
|---|---|
| Product Name: | Class-D Power Amplifier |
| Trademark: |   |
| Model/Type reference: | DA18K4<br>DA24K2, DA1004, DA1004D, DA1008, DA2004, DA2004D, DA2006, DA2008, DA2504, DA2506, DA2508, DA2504D, DA5002, DA5002D, DA5004, DA5004D, DA5008, DA20K4, DA15K4, DA10K4, DA30K2, DA18K2, DA12K2, DA9K2, DA20K4D, DA15K4D, DA10K4D, DA30K2D, DA18K2D, DA12K2D, DA9K2D |
| Prepared For: | SANWAY AUDIO EQUIPMENT CO LIMITED |
| Address: | 901 HUITONG APARTMENT, YONGFA ROAD, HUADU DISTRICT 510800, GUANGZHOU, GUANGDONG, CHINA |
| Manufacturer: | ZHAOQING SANWAY AUDIO CO., LIMITED |
| Address: | C40 WANYANG CROAD INNOVATION PARK, NO.41 DAWANG AVENUE, ZIP:526238 ZHAOQING NATIONAL HIGH-TECH ZONE, GUANGDONG, CHINA |
| Prepared By: | Shenzhen BCTC Testing Co., Ltd. |
| Address: | 1-2/F., Building B, Pengzhou Industrial Park, No.158, Fuyuan 1st Road, Tangwei, Fuhai Subdistrict, Bao'an District, Shenzhen, Guangdong, China |
| Sample Received Date: | 2021-11-12 |
| Sample tested Date: | 2021-11-13 to 2021-11-25 |
| Issue Date: | 2022-06-22 |
| Report No.: | BCTC2110418681E |
| Test Standards | EN 55032:2015+A1:2020, EN 55035: 2017+A11:2020<br>EN IEC 61000-3-2:2019, EN 61000-3-3:2013+A1:2019 |
| Test Results | PASS |

Tested by:

Lucas Chan /Project Handler

Approved by:

Zero Zhou/Reviewer

The test report is effective only with both signature and specialized stamp.This result(s) shown in this report refer only to the sample(s) tested. Without written approval of Shenzhen BCTC Testing Co., Ltd, this report can't be reproduced except in full.The tested sample(s) and the sample information are provided by the client.

Table Of Content

Test Report Declaration Page
1. Version ....5
2. Test Summary ....6
3. Measurement Uncertainty ....7
4. Product Information And Test Setup ....8
4.1 Product Information ....8
4.2 Test Setup Configuration ....8
4.3 Support Equipment ....8
4.4 Test Mode ....9
5. Test Facility And Test Instrument Used ....10
5.1 Test Facility ....10
5.2 Test Instrument Used ....10
6. Conducted Emissions ....13
6.1 Block Diagram Of Test Setup ....13
6.2 Limit ....13
6.3 Test procedure ....13
6.4 Test Result ....14
7. Radiated Emissions Test ....16
7.1 Block Diagram Of Test Setup ....16
7.2 Limits ....16
7.3 Test Procedure ....16
7.4 Test Results ....17
8. Harmonic Current Emission(H) ....19
8.1 Block Diagram of Test Setup ....19
8.2 Limit ....19
8.3 Test Procedure ....19
8.4 Test Results ....19
9. Voltage Fluctuations & Flicker(F) ....20
9.1 Block Diagram of Test Setup ....20
9.2 Limit ....20
9.3 Test Procedure ....20
9.4 Test Results ....21
10. Immunity Test Of General The Performance Criteria ....22
11. Electrostatic Discharge (ESD) ....23
11.1 Test Specification ....23
11.2 Block Diagram of Test Setup ....23
11.3 Test Procedure ....23
11.4 Test Results ....24
12. Continuous Rf Electromagnetic Field Disturbances (RS) ....25
12.1 Test Specification ....25
12.2 Block Diagram of Test Setup ....25
12.3 Test Procedure ....25
12.4 Test Results ....26

13. Electrical Fast Transients/Burst (EFT) ..... 27
13.1 Test Specification ..... 27
13.2 Block Diagram of EUT Test Setup ..... 27
13.3 Test Procedure ..... 27
13.4 Test Results ..... 27
14. Surges Immunity Test ..... 28
14.1 Test Specification ..... 28
14.2 Block Diagram of EUT Test Setup ..... 28
14.3 Test Procedure ..... 28
14.4 Test Result ..... 29
15. Continuous induced RF disturbances (CS) ..... 30
15.1 Test Specification ..... 30
15.2 Block Diagram of EUT Test Setup ..... 30
15.3 Test Procedure ..... 30
15.4 Test Result ..... 31
16. Voltage dips and interruptions (DIPS) ..... 32
16.1 Test Specification ..... 32
16.2 Block Diagram of EUT Test Setup ..... 32
16.3 Test Procedure ..... 32
16.4 Test Result ..... 32
17. Eut Photographs ..... 33
18. Eut Test Setup Photographs ..... 40

(Note: N/A means not applicable)

## 1. Version

| Report No. | Issue Date | Description | Approved |
|---|---|---|---|
| BCTC2110418681E | 2022-06-22 | Original | Valid |
| | | | |
| | | | |

## 2. Test Summary

The Product has been tested according to the following specifications:

| Emission | | |
|---|---|---|
| **Standard** | **Test Item** | **Test result** |
| EN 55032 | Conducted emissions from the AC mains power ports | Pass |
| EN 55032 | Asymmetric mode conducted emissions | N/A[1] |
| EN 55032 | Conducted differential voltage emissions | N/A[2] |
| EN 55032 | Radiated emissions | Pass |
| EN IEC 61000-3-2 | Harmonic current emission(H) | Pass |
| EN 61000-3-3 | Voltage fluctuations & flicker(F) | Pass |

| Immunity (EN 55035) | | |
|---|---|---|
| **Standard** | **Test Item** | **Test result** |
| EN 55035 | Electrostatic discharge (ESD) | Pass |
| EN 55035 | Continuous RF electromagnetic field disturbances(RS) | Pass |
| EN 55035 | Electrical fast transients/burst (EFT) | Pass |
| EN 55035 | Surges | Pass |
| EN 55035 | Continuous induced RF disturbances (CS) | Pass |
| EN 55035 | Broadband impulse noise disturbances, repetitive | N/A[3] |
| EN 55035 | Broadband impulse noise disturbances, isolated | N/A[3] |
| EN 55035 | Power frequency magnetic field (PFMF) | N/A[4] |
| EN 55035 | Voltage dips and interruptions (DIPS) | Pass |

Remark:
1. Applicable to ports listed above and intended to connect to cables longer than 3 m.
2. The Product has no antenna port.
3. Applicable only to CPE xDSL ports.
4. The Product doesn't contain any device susceptible to magnetic fields.

## 3. Measurement Uncertainty

Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the Product as specified in CISPR 16-4-2. This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of k=2.

| Test item | Value (dB) |
|---|---|
| Conducted Emission (150kHz-30MHz) | 3.20 |
| Radiated Emission(30MHz~1GHz) | 4.80 |

# 4. Product Information And Test Setup

## 4.1 Product Information

| | |
|---|---|
| **Ratings:** | Input：AC 230V / 50Hz<br>Output power：1800W ×4@8Ω；2800W ×4@4Ω |
| **Model difference:** | All models are identical except for the appearance color, the test model is DA18K4 and the test results are applicable to other tests. |

## 4.2 Test Setup Configuration

See test photographs attached in EUT TEST SETUP PHOTOGRAPHS for the actual connections between Product and support equipment.

## 4.3 Support Equipment

| No. | Device Type | Brand | Model | Series No. | Data Cable | Power Cord |
|---|---|---|---|---|---|---|
| 1. | Low-frequency signal generator | ZHONGXIN | TAG-101 | --- | --- | --- |

Notes:
1. All the equipment/cables were placed in the worst-case configuration to maximize the emission during the test.
2. Grounding was established in accordance with the manufacturer's requirements and conditions for the intended use.

## 4.4 Test Mode

| Test item | Test Mode | Test Voltage |
|---|---|---|
| Conducted emissions from the AC mains power ports (150KHz-30MHz) Class B | Working | AC230V/50Hz |
| Radiated emissions(30MHz-1GHz) Class B | Working | AC230V/50Hz |
| Harmonic current emission<br>Class A | Working | AC230V/50Hz |
| Voltage fluctuations & flicker(F) | Working | AC230V/50Hz |
| Electrostatic discharge (ESD)<br>☒Air Discharge: ±2,4,8kV<br>☒Contact Discharge: ±2,4kV<br>☒HCP & VCP: ±2,4kV<br>10 times each point/ | Working | AC230V/50Hz |
| Continuous RF electromagnetic field disturbances(RS)<br>80MHz-1000MHz, 1800MHz, 2600MHz,3500MHz,5000MHz<br>3V/m,80% AM<br>Front, Rear, Left, Right<br>H/V | Working | AC230V/50Hz |
| Electrical fast transients/burst (EFT)<br>☒1kV AC(Input)<br>☐0.5kV DC(Input)<br>☐0.5kV signal,Telec,control | Working | AC230V/50Hz |
| Surges<br>☒1kV Line-Line,<br>☒2kV Line-PE, N-PE<br>☐0.5kVDC(Input)<br>☐1KV,☐4KV signal,Telec, control<br>Line-Line:90°+1kV,270°-1kV<br>Line-PE:90°+2kV,270°-2kV<br>N-PE:90°-2kV,270°+2kV | Working | AC230V/50Hz |
| Continuous induced RF disturbances (CS) A<br>0.15MHz to 10MHz 3V,<br>10MHz-30MHz 3 to 1V,<br>30MHz-80MHz 1V<br>☒ AC( Input)<br>☐ DC(Input)<br>☐ signal, Telec, control | Working | AC 230V/50Hz |
| Voltage dips and interruptions (DIPS)<br>Less 5% 0.5P 10ms B<br>70% 25P 500ms C<br>Voltage Interruptions<br>less5% 250P 5000ms C | Working | AC 230V/50Hz |
| | | |

# 5. Test Facility And Test Instrument Used

## 5.1 Test Facility

All measurement facilities used to collect the measurement data are located at Shenzhen BCTC Testing Co., Ltd. Address: 1-2/F., Building B, Pengzhou Industrial Park, No.158, Fuyuan 1st Road, Tangwei, Fuhai Subdistrict, Bao'an District, Shenzhen, Guangdong, China. The site and apparatus are constructed in conformance with the requirements of ANSI C63.4 and CISPR 16-1-1 other equivalent standards.

## 5.2 Test Instrument Used

| Conducted Emissions Test | | | | | |
|---|---|---|---|---|---|
| **Equipment** | **Manufacturer** | **Model#** | **Serial#** | **Last Cal.** | **Next Cal.** |
| Receiver | R&S | ESR3 | 102075 | May 28, 2021 | May 27, 2022 |
| LISN | R&S | ENV216 | 101375 | May 28, 2021 | May 27, 2022 |
| ISN | HPX | ISN T800 | S1509001 | May 28, 2021 | May 27, 2022 |
| Software | Frad | EZ-EMC | EMC-CON 3A1 | \ | \ |

| Radiated Emissions Test (966 Chamber) | | | | | |
|---|---|---|---|---|---|
| **Equipment** | **Manufacturer** | **Model#** | **Serial#** | **Last Cal.** | **Next Cal.** |
| 966 chamber | ChengYu | 966 Room | 966 | Jun. 06. 2020 | Jun. 05, 2023 |
| Receiver | R&S | ESRP | 101154 | May 28, 2021 | May 27, 2022 |
| Receiver | R&S | ESR3 | 102075 | May 28, 2021 | May 27, 2022 |
| Amplifier | SKET | LAPA_01G18G-45dB | \ | May 28, 2021 | May 27, 2022 |
| Amplifier | Schwarzbeck | BBV9744 | 9744-0037 | May 28, 2021 | May 27, 2022 |
| TRILOG Broadband Antenna | schwarzbeck | VULB9163 | 942 | Jun. 01, 2021 | May 31, 2022 |
| Horn Antenna | schwarzbeck | BBHA9120D | 1541 | Jun. 02, 2021 | Jun. 01, 2022 |
| Software | Frad | EZ-EMC | FA-03A2 RE | \ | \ |

| Harmonic / Flicker Test | | | | | |
|---|---|---|---|---|---|
| **Equipment** | **Manufacturer** | **Model#** | **Serial#** | **Last Cal.** | **Next Cal.** |
| Harmonic & Flicker Tester | LAPLAEC | AC2000A | 439263 | May 31, 2021 | May 30, 2022 |
| AC Power Supply | KIKUSUI | PCR4000M | UK001879 | May 28, 2021 | May 27, 2022 |
| Software | Frad | EZ-EMC | FA-03A2 RE | \ | \ |

| Electrostatic Discharge Test | | | | | |
|---|---|---|---|---|---|
| **Equipment** | **Manufacturer** | **Model#** | **Serial#** | **Last Cal.** | **Next Cal.** |
| ESD Tester | KIKUSUI | KES4201A | UH002321 | May 31, 2021 | May 30, 2022 |

| Continuous RF Electromagnetic Field Disturbances Test | | | | | |
|---|---|---|---|---|---|
| **Equipment** | **Manufacturer** | **Model#** | **Serial#** | **Last Cal.** | **Next Cal.** |
| Power meter | Keysight | E4419 | \ | May 28, 2021 | May 27, 2022 |
| Power sensor | Keysight | E9300A | \ | May 28, 2021 | May 27, 2022 |
| Power sensor | Keysight | E9300A | \ | May 28, 2021 | May 27, 2022 |
| Amplifier | SKET | HAP_801000-250W | \ | May 28, 2021 | May 27, 2022 |
| Amplifier | SKET | HAP_0103-75W | \ | May 28, 2021 | May 27, 2022 |
| Amplifier | SKET | HAP_0306-50W | \ | May 28, 2021 | May 27, 2022 |
| Stacked double Log.-Per. Antenna | Schwarzbeck | STLP 9129 | \ | \ | \ |
| Field Probe | Narda | EP-601 | \ | Jun. 29, 2021 | Jun. 28, 2022 |
| Signal Generator | Agilent | N5181A | MY50143748 | Jun. 29, 2021 | Jun. 28, 2022 |
| Software | SKET | EMC-S | 1.2.0.18 | \ | \ |


| EFT And Surge And Voltage Dips And Interruptions Test | | | | | |
|---|---|---|---|---|---|
| **Equipment** | **Manufacturer** | **Model#** | **Serial#** | **Last Cal.** | **Next Cal.** |
| Compact Generator | TRANSIENT | TRA2000 | 646 | Jun. 29, 2021 | Jun. 28, 2022 |
| Coupling Clamp | PARTNER | CN-EFT1000 | CN-EFT1000 0-1624 | May 28, 2021 | May 27, 2022 |

| Continuous Induced RF Disturbances Test | | | | | |
|---|---|---|---|---|---|
| **Equipment** | **Manufacturer** | **Model#** | **Serial#** | **Last Cal.** | **Next Cal.** |
| C/S Test System | SCHLODER | CDG-6000-75 | 126B1405/2016 | May 28, 2021 | May 27, 2022 |
| Attenuator | SCHLODER | 6DB DC-1G | HA1630 | May 28, 2021 | May 27, 2022 |
| CDN | SCHLODER | CDN M2+M3 | A2210389/2016 | May 28, 2021 | May 27, 2022 |
| Injection Clamp | SCHLOBER | EMCL-20 | 132A1272/2016 | May 28, 2021 | May 27, 2022 |
| Software | HUBERT | HUBERT EN 61000-4-6 | 1.4.1.0 | \ | \ |

# 6. Conducted Emissions

## 6.1 Block Diagram Of Test Setup

**For mains ports:**




## 6.2 Limit

**Limits for Conducted emissions at the mains ports of Class B MME**

| Frequency range (MHz) | Limits dB(μV) | |
|---|---|---|
| | Quasi-peak | Average |
| 0,15 to 0,50 | 66 to 56* | 56 to 46* |
| 0,50 to 5 | 56 | 46 |
| 5 to 30 | 60 | 50 |


Notes: 1. *Decreasing linearly with logarithm of frequency.
2. The lower limit shall apply at the transition frequencies.

## 6.3 Test procedure

**For mains ports:**
a. The Product was placed on a nonconductive table 0. 8 m above the horizontal ground reference plane, and 0.4 m from the vertical ground reference plane, and connected to the main through Line Impedance Stability Network (L.I.S.N).
b. The RBW of the receiver was set at 9 kHz in 150 kHz ~ 30MHz with Peak and AVG detector in Max Hold mode. Run the receiver's pre-scan to record the maximum disturbance generated from Product in all power lines in the full band.
c. For each frequency whose maximum record was higher or close to limit, measure its QP and AVG values and record.

## 6.4 Test Result


| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Phase : | Line |
| Test Voltage : | AC 230V/50Hz | Test Mode: | Working |




Remark:
1. All readings are Quasi-Peak and Average values.
2. Factor = Insertion Loss + Cable Loss.

| No. | Mk. | Freq. | Reading Level | Correct Factor | Measure-ment | Limit | Over | |
|---|---|---|---|---|---|---|---|---|
| | | MHz | | dB | dBuV | dBuV | dB | Detector |
| 1 | | 0.1500 | 40.86 | 19.61 | 60.47 | 66.00 | -5.53 | QP |
| 2 | * | 0.1500 | 35.73 | 19.61 | 55.34 | 56.00 | -0.66 | AVG |
| 3 | | 0.1949 | 38.00 | 19.61 | 57.61 | 63.83 | -6.22 | QP |
| 4 | | 0.1949 | 31.95 | 19.61 | 51.56 | 53.83 | -2.27 | AVG |
| 5 | | 0.2444 | 33.08 | 19.61 | 52.69 | 61.95 | -9.26 | QP |
| 6 | | 0.2444 | 29.22 | 19.61 | 48.83 | 51.95 | -3.12 | AVG |
| 7 | | 0.8338 | 32.83 | 19.62 | 52.45 | 56.00 | -3.55 | QP |
| 8 | | 0.8338 | 22.62 | 19.62 | 42.24 | 46.00 | -3.76 | AVG |
| 9 | | 2.1613 | 33.22 | 19.63 | 52.85 | 56.00 | -3.15 | QP |
| 10 | | 2.1613 | 3.52 | 19.63 | 23.15 | 46.00 | -22.85 | AVG |
| 11 | | 10.9454 | 36.97 | 19.80 | 56.77 | 60.00 | -3.23 | QP |
| 12 | | 10.9454 | 18.98 | 19.80 | 38.78 | 50.00 | -11.22 | AVG |

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Phase : | Neutral |
| Test Voltage : | AC 230V/50Hz | Test Mode: | Working |





Remark:
1. All readings are Quasi-Peak and Average values.
2. Factor = Insertion Loss + Cable Loss.

| No. | Mk. | Freq. | Reading Level | Correct Factor | Measure-ment | Limit | Over | |
|---|---|---|---|---|---|---|---|---|
| | | MHz | | dB | dBuV | dBuV | dB | Detector |
| 1 | | 0.1500 | 43.34 | 19.61 | 62.95 | 66.00 | -3.05 | QP |
| 2 | * | 0.1500 | 34.69 | 19.61 | 54.30 | 56.00 | -1.70 | AVG |
| 3 | | 0.2442 | 31.71 | 19.61 | 51.32 | 61.95 | -10.63 | QP |
| 4 | | 0.2442 | 27.96 | 19.61 | 47.57 | 51.95 | -4.38 | AVG |
| 5 | | 0.8802 | 31.51 | 19.62 | 51.13 | 56.00 | -4.87 | QP |
| 6 | | 0.8802 | 23.18 | 19.62 | 42.80 | 46.00 | -3.20 | AVG |
| 7 | | 1.7253 | 31.57 | 19.63 | 51.20 | 56.00 | -4.80 | QP |
| 8 | | 1.7253 | 6.02 | 19.63 | 25.65 | 46.00 | -20.35 | AVG |
| 9 | | 7.0997 | 34.57 | 19.74 | 54.31 | 60.00 | -5.69 | QP |
| 10 | | 7.0997 | 10.37 | 19.74 | 30.11 | 50.00 | -19.89 | AVG |
| 11 | | 11.9327 | 36.64 | 19.79 | 56.43 | 60.00 | -3.57 | QP |
| 12 | | 11.9327 | 20.12 | 19.79 | 39.91 | 50.00 | -10.09 | AVG |

# 7. Radiated Emissions Test

## 7.1 Block Diagram Of Test Setup

**30MHz ~ 1GHz:**




## 7.2 Limits

**Limits for radiated disturbance of Class B MME**

| Frequency (MHz) | Quasi-peak limits at 3m dB(μV/m) |
|---|---|
| 30-230 | 40 |
| 230-1000 | 47 |

## 7.3 Test Procedure

**30MHz ~ 1GHz:**

a. The Product was placed on the nonconductive turntable 0.8 m above the ground in a semi anechoic chamber.


b. Set the spectrum analyzer/receiver in Peak detector, Max Hold mode, and 120 kHz RBW. Record the maximum field strength of all the pre-scan process in the full band when the antenna is varied between 1~4 m in both horizontal and vertical, and the turntable is rotated from 0 to 360 degrees.

c. For each frequency whose maximum record was higher or close to limit, measure its QP value: vary the antenna's height and rotate the turntable from 0 to 360 degrees to find the height and degree where Product radiated the maximum emission, then set the test frequency analyzer/receiver to QP Detector and specified bandwidth with Maximum Hold Mode, and record the maximum value.

## 7.4 Test Results

**30MHz ~ 1GHz:**


| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101KPa | Phase : | Horizontal |
| Test Voltage : | AC 230V/50Hz | Test Mode: | Working |




Remark:
Factor = Antenna Factor + Cable Loss – Pre-amplifier.

| No. | Mk. | Freq. | Reading Level | Correct Factor | Measure-ment | Limit | Over | |
|---|---|---|---|---|---|---|---|---|
| | | MHz | dBuV | dB | dBuV/m | dB/m | dB | Detector |
| 1 | ! | 34.1561 | 53.70 | -17.80 | 35.90 | 40.00 | -4.10 | QP |
| 2 | * | 50.9420 | 54.44 | -15.48 | 38.96 | 40.00 | -1.04 | QP |
| 3 | ! | 62.6507 | 55.30 | -16.73 | 38.57 | 40.00 | -1.43 | QP |
| 4 | ! | 116.9495 | 55.73 | -17.27 | 38.46 | 40.00 | -1.54 | QP |
| 5 | | 146.3735 | 51.31 | -19.25 | 32.06 | 40.00 | -7.94 | QP |
| 6 | | 306.7536 | 43.99 | -13.56 | 30.43 | 47.00 | -16.57 | QP |

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101KPa | Phase : | Vertical |
| Test Voltage : | AC 230V/50Hz | Test Mode: | Working |





Remark:
Factor = Antenna Factor + Cable Loss – Pre-amplifier.

| No. | Mk. | Freq. | Reading Level | Correct Factor | Measure-ment | Limit | Over | |
|---|---|---|---|---|---|---|---|---|
| | | MHz | dBuV | dB | dBuV/m | dB/m | dB | Detector |
| 1 | ! | 30.1051 | 56.54 | -18.43 | 38.11 | 40.00 | -1.89 | QP |
| 2 | ! | 34.8823 | 56.23 | -17.69 | 38.54 | 40.00 | -1.46 | QP |
| 3 | ! | 51.4806 | 54.26 | -15.51 | 38.75 | 40.00 | -1.25 | QP |
| 4 | * | 63.3132 | 55.76 | -16.91 | 38.85 | 40.00 | -1.15 | QP |
| 5 | ! | 94.4282 | 55.93 | -17.58 | 38.35 | 40.00 | -1.65 | QP |
| 6 | ! | 124.5690 | 56.49 | -17.78 | 38.71 | 40.00 | -1.29 | QP |

# 8. Harmonic Current Emission(H)

## 8.1 Block Diagram of Test Setup




## 8.2 Limit

EN IEC 61000-3-2:2019.

## 8.3 Test Procedure

a. The Product was placed on the top of a non-conductive table above the ground and operated to produce the maximum harmonic components under normal operating conditions for each successive harmonic component in turn.
b. The correspondent test program of test instrument to measure the current harmonics emanated from Product was chosen. The measure time shall be not less than the time necessary for the Product to be exercised.


## 8.4 Test Results

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |

**PASS**

# 9. Voltage Fluctuations & Flicker(F)

## 9.1 Block Diagram of Test Setup




## 9.2 Limit

EN 61000-3-3:2013+A1:2019 Clause 5.

## 9.3 Test Procedure

a. The Product was placed on the top of a non-conductive table above the ground and operated to produce the most unfavorable sequence of voltage changes under normal operating conditions.
b. During the flick test, the measure time shall include that part of whole operation cycle in which the Product produce the most unfavorable sequence of voltage changes. The observation period for short-term flicker indicator is 10 minutes and the observation period for long-term flicker indicator is 2 hours.

## 9.4 Test Results

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |

**Test duration (sec):600**

**Describe:**

**Load Power : 0.112 kW** **Power Factor:0.423**

**Load Current : 1.148 Arms** **Crest Factor:2.497**

**Nominal Voltage : 230.26 Vrms**

**Test Result: pass** **Status: Test Completed**

**Result:**

| | | | | |
|---|---|---|---|---|
| **T-max (ms):** | **0.00** | **Test limit (ms):** | **500.00** | **Pass** |
| **Highest dc (%):** | **0.00** | **Test limit (%):** | **3.30** | **Pass** |
| **Highest dmax (%):** | **0.00** | **Test limit (%):** | **4.00** | **Pass** |
| **Highest Pst (10 min. period):** | **0.000** | **Test limit:** | **1.000** | **Pass** |

## 10. Immunity Test Of General The Performance Criteria

| Product Standard | EN 55035: 2017+A11:2020 clause 8 |
|---|---|
| **CRITERION A** | The equipment shall continue to operate as intended without operator intervention. No degradation of performance, loss of function or change of operating state is allowed below a performance level specified by the manufacturer when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended. |
| **CRITERION B** | During the application of the disturbance, degradation of performance is allowed. However, no unintended change of actual operating state or stored data is allowed to persist after the test.<br>After the test, the equipment shall continue to operate as intended without operator intervention; no degradation of performance or loss of function is allowed, below a performance level specified by the manufacturer, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.<br>If the minimum performance level (or the permissible performance loss), or recovery time, is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended. |
| **CRITERION C** | Loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls by the user in accordance with the manufacturer's instructions. A reboot or re-start operation is allowed.<br>Information stored in non-volatile memory, or protected by a battery backup, shall not be lost. |


# 11. Electrostatic Discharge (ESD)

## 11.1 Test Specification

| | | |
|---|---|---|
| **Test Port** | : | Enclosure port |
| **Discharge Impedance** | : | 330 ohm / 150 pF |
| **Discharge Mode** | : | Single Discharge |
| **Discharge Period** | : | one second between each discharge |

## 11.2 Block Diagram of Test Setup

For Floor Stand:




## 11.3 Test Procedure

a. Electrostatic discharges were applied only to those points and surfaces of the Product that are accessible to users during normal operation.
b. The test was performed with at least ten single discharges on the pre-selected points in the most sensitive polarity.
c. The time interval between two successive single discharges was at least 1 second.
d. The ESD generator was held perpendicularly to the surface to which the discharge was applied and the return cable was at least 0.2 meters from the Product.
e. Contact discharges were applied to the non-insulating coating, with the pointed tip of the generator penetrating the coating and contacting the conducting substrate.
f. Air discharges were applied with the round discharge tip of the discharge electrode approaching the Product as fast as possible (without causing mechanical damage) to touch the Product. After each discharge, the ESD generator was removed from the Product and re-triggered for a new single discharge. The test was repeated until all discharges were complete.
g. At least ten single discharges (in the most sensitive polarity) were applied to the center of one vertical edge of the Vertical Coupling Plane in sufficiently different positions that the four faces of the Product were completely illuminated. The VCP (dimensions 0.5m x 0.5m) was placed vertically to and 0.1 meters from the Product.

## 11.4 Test Results

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |

| Discharge Method | Discharge Position | Voltage (±kV) | Min. No. of Discharge per polarity (Each Point) | Required Level | Performance Criterion |
|---|---|---|---|---|---|
| Contact Discharge | Conductive Surfaces | 4 | 10 | B | A |
| | Indirect Discharge HCP | 4 | 10 | B | A |
| | Indirect Discharge VCP | 4 | 10 | B | A |
| Air Discharge | Slots, Apertures, and Insulating Surfaces | 8 | 10 | B | A |
| Note: N/A | | | | | |


# 12. Continuous Rf Electromagnetic Field Disturbances (RS)

## 12.1 Test Specification

| | | |
|---|---|---|
| **Test Port** | : | Enclosure port |
| **Step Size** | : | 1% |
| **Modulation** | : | 1kHz, 80% AM |
| **Dwell Time** | : | 1 second |
| **Polarization** | : | Horizontal & Vertical |

## 12.2 Block Diagram of Test Setup

Below 1GHz:




## 12.3 Test Procedure

a. The testing was performed in a fully-anechoic chamber. The transmit antenna was located at a distance of 3 meters from the Product.
b. The frequency range is swept from 80MHz to 1000MHz, 1800MHz, 2600MHz, 3500MHz, 5000MHz,with the signal 80% amplitude modulated with a 1 kHz sine wave,and the step size was 1%.
c. The dwell time at each frequency shall not be less than the time necessary for the EUT to be exercised and to be able to respond, but should not exceed 5 s at each of the frequencies during the scan.
d. The test was performed with the Product exposed to both vertically and horizontally polarized fields on each of the four sides.
e. For Broadcast reception function:Group 2 not apply in this test.

## 12.4 Test Results

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |

| Frequency | Position | Field Strength (V/m) | Required Level | Performance Criterion |
|---|---|---|---|---|
| 80 - 1000MHz, 1800MHz, 2600MHz, 3500MHz, 5000MHz | Front, Right, Back, Left | 3 | A | A |
| Note: N/A | | | | |


# 13. Electrical Fast Transients/Burst (EFT)

## 13.1 Test Specification

| | | |
|---|---|---|
| **Test Port** | : | input ac/dc. power port |
| **Impulse Frequency** | : | 5 kHz |
| **Impulse Wave-shape** | : | 5/50 ns |
| **Burst Duration** | : | 15 ms |
| **Burst Period** | : | 300 ms |
| **Test Duration** | : | 2 minutes per polarity |

## 13.2 Block Diagram of EUT Test Setup

**For input ac/dc. power port:**




## 13.3 Test Procedure

a. The Product and support units were located on a non-conductive table above ground reference plane.

b. A 0.5m-long power cord was attached to Product during the test.

## 13.4 Test Results

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |


| Coupling | Voltage (kV) | Polarity | Required Level | Performance Criterion |
|---|---|---|---|---|
| AC MainsL-N-P | 1.0 | ± | B | A |
| Note: N/A | | | | |

# 14. Surges Immunity Test

## 14.1 Test Specification

| | | |
|---|---|---|
| **Test Port** | : | input ac/dc. power port |
| **Wave-Shape** | : | Open Circuit Voltage - 1.2 / 50 us<br>Short Circuit Current - 8 / 20 us |
| **Pulse Repetition Rate** | : | 1 pulse / min. |
| **Phase Angle** | : | 0° / 90° / 180° / 270° |
| **Test Events** | : | 5 pulses (positive & negative) for each polarity |

## 14.2 Block Diagram of EUT Test Setup




## 14.3 Test Procedure

a. The surge is to be applied to the Product power supply terminals via the capacitive coupling network. Decoupling networks are required in order to avoid possible adverse effects on equipment not under test that may be powered by the same lines, and to provide sufficient decoupling impedance to the surge wave.
b. The power cord between the Product and the coupling/decoupling networks shall be 2 meters in length (or shorter). Interconnection line between the Product and the coupling/decoupling networks shall be 2 meters in length (or shorter).

## 14.4 Test Result

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |

| Coupling Line | Voltage (kV) | Phase Angle | Required Level | Performance Criterion |
|---|---|---|---|---|
| L - N | + 1 | 90° | B | A |
| | - 1 | 270° | | |
| L - PE | + 2 | 90° | B | A |
| | - 2 | 270° | | |
| N - PE | + 2 | 90° | B | A |
| | - 2 | 270° | | |
| Note:N/A | | | | |


# 15. Continuous induced RF disturbances (CS)

## 15.1 Test Specification

| | | |
|---|---|---|
| **Test Port** | : | input ac/dc. power port |
| **Step Size** | : | 1% |
| **Modulation** | : | 1kHz, 80% AM |
| **Dwell Time** | : | 1 second |

## 15.2 Block Diagram of EUT Test Setup

**For input ac/ac. power port:**




## 15.3 Test Procedure

**For input ac/dc. power port:**
a. The Product and support units were located at a ground reference plane with the interposition of a 0.1 m thickness insulating support and the CDN was located on GRP directly.
b. The frequency range is swept from 150 kHz to 10MHz, 10MHz to 30MHz, 30MHz to 80MHz with the signal 80% amplitude modulated with a 1 kHz sine wave, and the step size was 1% of fundamental.
c. The dwell time at each frequency shall be not less than the time necessary for the Product to be able to respond.

## 15.4 Test Result

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |


| Inject Line | Frequency (MHz) | Voltage Level (V r.m.s.) | Required Level | Performance Criterion |
|---|---|---|---|---|
| a.c. port | 0.15 - 10 | 3 | A | A |
| | 10 to 30 | 3 to 1 | A | A |
| | 30 to 80 | 1 | A | A |
| Note: N/A | | | | |

# 16. Voltage dips and interruptions (DIPS)

## 16.1 Test Specification

| | | |
|---|---|---|
| **Test Port** | : | input ac. power port |
| **Phase Angle** | : | 0°, 180° |
| **Test cycle** | : | 3 times |

## 16.2 Block Diagram of EUT Test Setup




## 16.3 Test Procedure

a. The Product and support units were located on a non-conductive table above ground floor.
b. Set the parameter of tests and then perform the test software of test simulator.
c. Conditions changes to occur at 0 degree crossover point of the voltage waveform.


## 16.4 Test Result

| | | | |
|---|---|---|---|
| Temperature: | 26 ℃ | Relative Humidity: | 54% |
| Pressure: | 101kPa | Test Mode: | Working |
| Test Voltage : | AC 230V/50Hz | | |

| **Test Level % $U_T$** | **Voltage dips in % $U_T$** | **Duration ( ms)** | **Required Level** | **Performance Criterion** |
|---|---|---|---|---|
| < 5 | ≥95 | 10 | B | A |
| 70 | 30 | 500 | C | A |
| **Voltage Interruptions:** | | | | |
| < 5 | ≥95 | 5000 | C | B* |
| Note*: The EUT Unable to working during testing, and it end of the test can be restored automatically. | | | | |

## 17. Eut Photographs

EUT Photo 1




EUT Photo 2




EUT Photo 3




EUT Photo 4




EUT Photo 5




EUT Photo 6




EUT Photo 7




EUT Photo 8




EUT Photo 9




EUT Photo 10




EUT Photo 11




EUT Photo 12



EUT Photo 13



EUT Photo 14




## 18. Eut Test Setup Photographs

Conducted emissions




Radiated emissions




H/F


测试布置图布置
参考标准：
IEC 61000-3-2 IEC 61000-3-3
EN 61000-3-2 EN 61000-3-3
AC Mains
AC Power Source
EUT
LAPLACE INSTRUMENTS LTD


ESD




RS



EFT & Dips & Surge



CS



# STATEMENT

1.The equipment lists are traceable to the national reference standards.

2.The test report can not be partially copied unless prior written approval is issued from our lab.

3.The test report is invalid without stamp of laboratory.

4.The test report is invalid without signature of person(s) testing and authorizing.

5.The test process and test result is only related to the Unit Under Test.

6.The quality system of our laboratory is in accordance with ISO/IEC17025.

7.If there is any objection to report, the client should inform issuing laboratory within 15 days from the date of receiving test report.

Address:
1-2/F., Building B, Pengzhou Industrial Park, No.158, Fuyuan 1st Road, Tangwei, Fuhai Subdistrict, Bao'an District, Shenzhen, Guangdong, China

TEL：400-788-9558

P.C.: 518103

FAX：0755-33229357

Website：http://www.chnbctc.com

E-Mail：bctc@bctc-lab.com.cn

※※※※※ **END** ※※※※※